

Fire Sprinkler System NFPA 5 Year Inspections

Two commonly asked questions:

Who is requiring these inspections?

The State of Utah has adopted as part of its rules in R710-5-6 the following code and amendment:

Automatic Fire Sprinkler Systems **shall be inspected** for obstructions **every five years** by a person holding a certificate of registration, as required in Section 3.1.

Automatic Fire Sprinkler Systems that pass the Five Year requirement **shall have a label affixed** to the riser indicating the month and year the **Five Year Inspection** was performed, the type of inspection and the individual's certificate of registration.

What additional is required for a 5 year inspection?

Specific Information and details are provided in NFPA 25.

Internal inspections of the following system components are required:

- System Valves
- Risers
- Cross mains
- Branch lines
- Gauges

Info Provided by

